

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Southwest Warren County Municipal Authority Did Not Meet Treatment Requirements

Our water system recently violated a drinking water standard. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did to correct this situation.

We routinely monitor your water for turbidity (cloudiness). This tells us whether we are effectively filtering the water supply. The combined Filter Effluent exceeded 1.0 NTU for over 95% of the collected samples for the month of March 2026.

What should I do?

You do not need to take actions. We do not know of any contamination, and none of our testing has shown disease-causing organisms in the drinking water.

People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

What does this mean?

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. These symptoms are not caused only by organisms in drinking water. If you experience any of these symptoms and they persist, you may want to seek medical advice.

What happened? What is being done?

A problem occurred with the treatment system at the water plant. During the month of March 2026 the water treatment plant experienced high levels of combined effluent turbidity. Maintenance work will be conducted on the filter bays to resolve the issue and improve the treatment process.

We anticipate resolving the problem by June 1st 2026.

For more information, please contact SWCMA - Amanda Messel at 814-484-7424 or Tboro@tidioute.org.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Southwest Warren County Municipal Authority.

PWS ID#: 6620032

Date distributed: 5/1/2026