

Form



Pennsylvania
Department of
Environmental Protection

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

PUBLIC NOTICE

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO MONITOR**

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA ÚSTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Southwest Warren County Municipal Authority

Our water system violated one or more drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During April 2026 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Combined Filter Effluent Turbidity measurements	2880	2388	April 2026	Continuously recorded at 15-minute intervals
Individual Filter Effluent Turbidity measurements	2880	2388	April 2026	Continuously recorded at 15-minute intervals

What happened? What was done? When will it be resolved?

The water treatment plant monitoring equipment failed to record all the turbidity measurements taken during April 2026 due to power issues with the recording equipment. A new uninterrupted power supply was installed for the recorder in April of 2026.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Amanda Messel at SWCMA Office at 814-484-7424.

Certified by:

Signature: _____ **Date:** _____

Print Name and Title: _____

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: _____